

1 Q. **B-25, Replace Emergency Diesel Generator, \$611,400**

2 In each of the past years from 2001 to 2010, how many times have all of the units
3 that might supply station service been off line at the same time?

4
5 A. The following table indicates how many times Bay d'Espoir Units 1 and 3 have been
6 offline at the same time in each of the past years from 2001 to 2010.

Year	No of Occurrences
2001	5
2002	2
2003	2
2004	2
2005	3
2006	3
2007	0
2008	1
2009	0
2010	4

7 The information is not available in Hydro's Generation Equipment Status (GES)
8 database to document the circumstances around each of these coincident outages.
9 Under controlled conditions, Units 1 and 3 may be taken off at the same time,
10 provided that an alternate station service supply is established using a local station
11 service feeder. It is when these units go offline in an uncontrolled manner (e.g., an
12 unscheduled outage to the entire plant) and the feeder is unavailable, that the
13 diesel generator is required to restore essential station service loads in an
14 expedient manner.