

1 Q. **B-29, Install Additional 230 kV Transformer, \$3,535,200**

2 Is it possible to specify an impedance value (range) for the proposed T4 addition at
3 Oxen Pond in order to minimize the loss of firm capacity due to the mismatch of
4 impedances?

5

6

7 A. When Hydro prepares the specification for a new power transformer to be placed in
8 parallel with existing units, the specification includes the impedance data for the
9 existing units so that the manufacturer can match the impedance of the new unit to
10 those already in service. Hydro transformers are manufactured to standard
11 CAN/CSA-C88-M90 Power Transformers and Reactors, Electrical Power Systems and
12 Equipment, a National Standard of Canada. Section 14 of CAN/CSA-C88-M90
13 provides the tolerances to be applied to a number of rated quantities which are
14 subject to manufacturer's guarantees. Table 9 of the standard indicates that the
15 impedance at rated current for a two winding transformer must be within $\pm 7.5\%$ of
16 the guaranteed value during specification/bid.

17

18 The existing transformer impedances in the Hardwoods – Oxen Pond Loop are
19 summarized in Table 1 below. The average impedance of the seven 230/66 kV
20 power transformers in the Hardwoods – Oxen Pond Loop is 8.75%. The variation of
21 each transformer to the loop average impedance is within the range specified in
22 CAN/CSA-C88-M90, Section 14.

23

24 Based upon the standards Hydro will specify a transformer impedance on the order
25 of 8.75% for Oxen Pond T4, with the manufacturer's tolerance being an impedance
26 in the range 8.09% to 9.4%. This will minimize the loss of firm capacity due to
27 impedance mismatch.

Transformer	Impedance %	Variation from average - %
Hardwoods T1	8.30	-5.14
Hardwoods T2	9.12	+4.22
Hardwoods T3	8.45	-3.42
Hardwoods T4	8.80	+0.57
Oxen Pond T1	8.85	+1.14
Oxen Pond T2	9.02	+3.08
Oxen Pond T3	8.73	-0.22
Average	8.75	