

1 Q. **B-29, Install Additional 230 kV Transformer, \$3,535,200**

2 Can B1L36 and B1L18 from Oxen Pond be used as spares for other breakers on the
3 system?

4

5

6 A. Oxen Pond circuit breakers B1L36 and B1L18 are Brown Boveri DCVF air blast circuit
7 breakers. At present, Hydro owns and operates 32 circuit breakers of this type on
8 the Island Interconnected System. It is intended to retire the two circuit breakers at
9 Oxen Pond and use them as spares/spare parts for the remaining 30 breakers in the
10 fleet.