1 (	Q.	B-36, Perform Wood Pole Management Program,	\$2,513,300
-----	----	---	-------------

- 2 For each of the years from 2008 to 2011 please provide the reliability statistics for
- 3 line TL-240 in Labrador.

4 5

6 A. Transmission Line TL-240 supplies the Happy Valley Delivery Point. The reliability

7 statistics for this delivery point are as follows:

## Delivery Point Performance of Happy Valley

Year	T-SAIFI	T-SAIDI
2008	9.00	49.00
2009	3.00	15.00
2010	5.00	186.00
2011 YTD		
(8/31/2011)	2.50	141.00
Hydro (2006-2010)	1.08	56.07
CEA (2005-2009)	0.73	70.72

T-SAIFI is the System Average Interruption Frequency Index. This index provides a measure of the average number of sustained interruptions that a delivery point experiences during a specified period.

T-SAIDI is the System Average Interruption Duration Index. This index provides a measure of the average duration of sustained interruptions that a delivery point experiences during a specified period.