

1 Q. Re: Holyrood: Upgrade Unit 1 Stack Breeching

2 With respect to the aspect of the Project that is comprised of "insulating the  
3 breeching externally complete with water tight cladding and flashing", was this the  
4 'long term solution' that the Board refers to at p. 10, lines 29 - 31 of P.U. No. 38  
5 (2010)?

6

7

8 A. Yes, that is Hydro's interpretation. It should be noted that the long term solution is  
9 also the most economic for the nine year estimated remaining life of Holyrood as a  
10 thermal generating station.