

1 Q. Re: Holyrood: Upgrade Unit 1 Stack Breaching

2 Given that the Hydro's most current base case is to operate Holyrood for the period
3 2017 to 2020 at just 32,000 barrels of oil per year, why is it stated in Section 4.3
4 (Cost Benefit Analysis) that the study period for the Cost Benefit Analysis was 9
5 years, this year period being described as the "minimum service life expected of the
6 breaching system which is dependent on the future of Holyrood as a generating
7 station."?

8

9

10 A. The cost benefit analysis is based on a nine-year period whereby the plant has to be
11 in reliable condition to operate at full thermal production if called upon. Thermal
12 production requirements are forecast to be high until the end of 2016. From 2017
13 to 2020, it is also possible that a scenario could develop whereby Holyrood would
14 be called upon to produce power for a significant period of time. For reliability of
15 the Island Interconnected System, it is prudent to ensure that Holyrood can deliver
16 full production for an extended period if called upon.

17

18 The nine-year analysis period is referred to as the "minimum service life" within the
19 context that this would be the requirement for thermal generation with the Lower
20 Churchill Project receiving sanction. If the Lower Churchill Project does not receive
21 sanction, or delays occur in the project schedule, then the service life of the
22 Holyrood plant as a primary power thermal generation plant would increase beyond
23 the minimum nine-year period.