

1 Q. **Fuel Oil Storage Facility:** With reference to page 11-93 of the Holyrood Condition
2 Assessment and Life Extension Study report filed with the Board on May 2, 2011,
3 does Hydro agree that the techno-eco risk and safety risk from corrosion of Tank 3
4 is low?

5

6

7 A. It should be noted, that AMEC, in its assessment, assumed that the multi-year tank
8 farm capital was approved and completion of this work would result in a very low
9 risk going forward. Pages 11-89 and 11-90 of the Holyrood Condition Assessment
10 and Life Extension Study speak to this issue, as well as the summary table on page
11 11-91. Assuming this project is approved and completed, Hydro agrees with the
12 risk assessment.