

---

1 Q. [Account G03 - Generators] - Please identify all current plans to retire any of the  
2 Company's investment in Account G03 - Generators. Further, provide all  
3 documentation in support of any plans to retire any of the assets.

4

5

6 A. See CA-NLH-178, Attachment 1 for a list of capital projects currently planned that  
7 will result in the retirement of investment in Account G03 - Generators. There is no  
8 documentation in support of specific plans to retire these assets. The  
9 documentation supports the related replacement or upgrade project and not the  
10 assets that will be retired once they are placed in-service. Assets will be retired  
11 upon replacement and any upgrades will result in a partial retirement of the original  
12 asset.

**Planned Capital Projects Resulting in Retirements for Account G03 - Generators**

<b>Project Description</b>	<b>Original In-Service Date</b>	<b>Total (\$000)</b>	<b>In-Service Year</b>
Upgrade Unit 4 Generator Bearing - Bay d'Espoir	1967	304	2013
Upgrade Unit 1 and 2 Generator Bearing - Bay d'Espoir	1967	402	2014
Rewind Generator 1 - Holyhood	1968	6,106	2014
Overhaul Unit 2 Steam Turbine Generator - Thermal - Holyhood	1968	4,500	2014
Upgrade Unit 3 Generator Bearing - Bay d'Espoir	1967	224	2015
Rewind Generator 2 - Holyhood	1968	5,796	2015
Refurbish Generation Unit - Snook's Arm	1956	1,226	2015
Refurbish Generation Unit - Venam's Bight	1956	464	2016
Rewind Generator 3 and Install Rotor Flux Probe - Holyhood	1980	8,402	2016
Overhaul Unit 3 Steam Turbine Generator - Thermal - Holyhood	1980	4,810	2016
Upgrade Unit 5 Generator Bearing - Bay d'Espoir	1970	190	2017
Replace Main Generator Bearing - Upper Salmon	1982	300	2017