

1 Q. [Account T05 - Transformers] - Regarding the two large power transformers retired  
2 at age 14.5 years as set forth in the Attachment in CA-NLH-137, please state if such  
3 transformers were used elsewhere in the system and if not why not.

4

5

6 A. The two large transformer assets set forth in CA-NLH-137 Attachment 1 were not  
7 used elsewhere in the Hydro system. Upon decommissioning of the Hope Brook  
8 Terminal Station, these assets were sold to a third party. They were sold because  
9 these transformers were 138 kV to 4160 V which were unique to the Hope Brook  
10 location and were not suitable to be used at another location.