

- 1 Q. Please identify whether the Holyrood plant assets, other than the Holyrood  
2 Synchronous assets, are planned for retirement. If the assets will not retire, please  
3 discuss their future use.  
4  
5
- 6 A. The Holyrood plant assets, other than those used to support the Holyrood  
7 synchronous condenser mode of operation, are planned for retirement by no later  
8 than 2020.