

-
- 1 Q. Please refer to the response to CA-NLH-182. The response states that Ohio Brass
2 polymer horizontal line post insulators were subject to continuous failures. Have all
3 insulators of this type been replaced? If no, what percent of the investment in
4 Account I03, Insulators, is associated with these insulators? Does Hydro have any
5 plans for replacing the remaining Ohio Brass insulators?
6
7
- 8 A. All of the Ohio Brass polymer horizontal line post insulators have been replaced.