

Undertaking - 102

Filed: Nov 13, 2015 Board Secretary: SK

Undertaking 102

Re: PR-DD-NLH-012

Undertaking to provide report of the August 6-7 2015 outage

Please see Undertaking 102, Attachment 1, which is the Public Utilities Board Advisory Form related to this item.

**PUBLIC UTILITIES BOARD
POWER OUTAGE and INCIDENT ADVISORY FORM**

PUB Number: 2015-H-244-a**Section A: General Information**

Company: Newfoundland and Labrador Hydro	Date Filed: August 07, 2015
Contact Information: NLH Regulatory Department	Email: NLHRegulatory@nlh.nl.ca

Section B: Initial Advisory - Details of Incident

Type of Incident: <i>Check all applicable</i>		
<input type="checkbox"/> Power Outage	<input type="checkbox"/> Damage to Company Property	<input type="checkbox"/> Damage to Customer Property
<input type="checkbox"/> Injury to Employee	<input type="checkbox"/> Injury to Member of Public	<input type="checkbox"/> Contact with Distribution system
<input checked="" type="checkbox"/> Other (explain in details)		

Date of Incident: August 06, 2015	Time of Incident: 2147 hours
Location of Incident: Holyrood Combustion Turbine	
Number of Customers Affected: N/A	
Duration of Power Outage: Please see below	
Is power outage still occurring? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes	
If yes, give estimation when power is expected to be restored:	
Description of Problem:	
<u>Holyrood Combustion Turbine – (123.5 MW) – Unavailable</u>	
At 2147 hours, August 06, 2015, the Holyrood Combustion Turbine tripped offline and became unavailable. The unit was generation at approximately 40 MW at the time of the trip, no customers were affected.	
Hydro's investigation determined an issue with a thermocouple was the cause of the trip. The issue has since been resolved and the unit became available at 0859 hours, August 07, 2015.	
Date Board Acknowledged: 2015-08-12 – C. Jones	

Section C: Final Disposition

The Board has reviewed the information filed with respect to this incident and has determined that the information filed is deemed satisfactory. The report has been filed and accepted by the Board.

Board Secretary or designate	Date:
------------------------------	-------