

1 Q. Please provide the current status on the project size, cost and in-service date.

2

3

4 A. The combustion turbine plant has an expected net output of 128.8 MW at 15
5 degrees Celsius ambient temperature, 60% relative humidity and ambient pressure
6 at sea level. The project budget is \$118,925,000 and the planned in-service date is
7 Dec. 7, 2014.