Page 1 of 1

1	Q.	Please confirm the type of fuel this unit will use, the current price and projected
2		cost of a 30 days continuous usage.
3		
4		
5	A.	This unit will use ASTM D2880 – No. 2 GT Gas Turbine fuel. Current contract pricing
ŝ		for the supply of oil of this specification is \$0.8669/litre. The projected cost of a 30-
7		day continuous usage is \$26.74 million.