

1 Q. Please confirm if the supply of fuel to the unit will come from the existing tank farm
2 or from a new tank source. If a new source, please provide certification for this
3 installation by all required authorities.

4

5

6 A. New fuel oil storage tanks dedicated for the use of the unit are within the scope of
7 supply of the EPC contactor. These tanks will not be connected to the existing fuel
8 storage tanks in place at the Holyrood site. Design of these tanks for certification is
9 within the scope of the EPC contractor. Draft drawings have been received by Hydro
10 for review; however, finalized design drawings for application to required
11 authorities for certification have not yet been received from the EPC contractor.