

1 Q. Please confirm if the major components of this Unit had been protected by a  
2 nitrogen blanket. If so, please provide the documentation.

3

4

5 A. The unit had been protected in accordance with storage guidelines prepared by the  
6 manufacturer. Please see Attachment 2 of Hydro's response to GT-CA-NLH-005.

7 These guidelines do not require that a nitrogen blanket be applied and one was not  
8 applied.