

1 Q. Please describe the amount of fuel storage that will be available for the 100 MW
2 combustion turbine.

3

4

5 A. The amount of fuel storage that will be available for the new combustion turbine is
6 660,000 US gallons.