

- 1 Q. On page 36 of *Supply and Install 100 MW (Nominal) of Combustion Turbine*
2 *Generation* report, Hydro states:
3 ***“While synchronous condenser capability is a desirable feature, if its provision***
4 ***would mean delays in the initial in service date of the combustion turbine, it***
5 ***would not be considered critical. This capability will not be required until 2017 and***
6 ***it can be pursued later.”***
7 Does the combustion turbine that Hydro has procured have synchronous condenser
8 capability?
9
10
11 A. The combustion turbine that Hydro has procured does not have synchronous
12 condenser capability.