

1 Q. Update Table 1 on page 1 of the Report to provide the actual LOLH for 2013 and for
2 2014 using actual to May 31, 2014 and forecast for the remainder of the year.

3

4

5 A. Please see updated Table 1a, below.

6

7

Table 1: Island System Loss of Load Hours (LOLH) from Report

8

2013 - 2020

9

2013	2014	2015	2016	2017	2018	2019	2020
0.97	2.48	3.85	5.10	4.98	0.15	0.16	0.16

10

11 The LOLH for 2013 and 2014 in Table 1a has been updated using actual monthly
12 peak demands for 2013 and up to May 31, 2014 and forecast for the remainder of
13 2014. Thermal generation reliability indicators (UFOPs and DAFORs) were not
14 updated. The new 120 MW combustion turbine is assumed to be in-service in
15 December 2014.

16

17 **Table 1a: Island System Loss of Load Hours (LOLH) – Updated 2013 and 2014**

18

2013 - 2020

19

2013	2014
0.92	3.40