

1 Q. On page 2 of the Report it is stated that the new generation capacity addition will
2 provide required system security for potential transmission contingencies after the
3 completion of the Muskrat Falls Project. What contingencies are being referred to
4 in the Report?

5

6

7 A. The Report refers to the following potential transmission contingencies after the
8 completion of the Muskrat Falls Project:

9

- 10 • Sustained interruption of supply over the Labrador-Island HVdc Link due to
11 single pole interruptions or in the unlikely event of bipole interruptions;
12 • Sustained interruption of supply over the 230 kV transmission lines into the
13 Avalon Peninsula; and
14 • Sustained single 230 kV transmission line outages, which limit transfer
15 capability to the Avalon Peninsula.