

1 Q. Explain in detail why and how a larger generation unit would aid such integration.

2

3

4 A. An HVdc converter station utilizing the line commutated converter technology such  
5 as the Soldiers Pond converter station requires a considerable amount of reactive  
6 power (MVAR) in the ac to dc and dc to ac conversion processes. Detailed  
7 transmission planning analyses of the Labrador-Island HVdc Link (LIL) revealed that  
8 in addition to the reactive power provided by the converter station ac harmonic  
9 filters, additional reactive power sources were required near the Soldiers Pond  
10 converter station. The operation of Holyrood Unit 3 in synchronous condenser  
11 mode following completion of the LIL provides a portion of the required reactive  
12 power. However, this alone is insufficient to ensure acceptable system operation  
13 and performance during system contingencies such as a transmission line fault.  
14 Analysis revealed the requirement for high inertia synchronous condensers to  
15 provide not only the necessary reactive power but also the inertia, or spinning  
16 mass, to assist in frequency response of the system during LIL contingencies. In  
17 optimizing the size of the high inertia synchronous condensers, a maximum of three  
18 175 MVAR units (two in service at all times – one out for maintenance as per the  
19 transmission planning criteria for LIL) provided sufficient inertia to assist in  
20 frequency response. However, the synchronous condenser package of Holyrood  
21 Unit 3 in synchronous condenser mode and two, 175 MVAR high inertia  
22 synchronous condensers at Soldiers Pond are approximately 120 MVAR short of the  
23 reactive power capability required. Prior to the decision to proceed with the option  
24 to acquire the unused 120 MW combustion turbine previously built due to its low  
25 cost and early availability, the plan was to add a nominal 60 MW combustion  
26 turbine in 2015 built in accordance with Hydro's specification. Proceeding with a  
27 Hydro specified unit would have provided the option to specify the supplier

1 manufacture a plant that has an alternator capable of providing the 120 MVAR  
2 synchronous condenser capability.

3  
4 In reference to a nominal 60 MW combustion turbine, the normal sized alternator  
5 would provide between 52 and 63 MVAR of reactive power capability when  
6 operated as a synchronous condenser. Installing a larger alternator with a nominal  
7 rating of 166 MVA connected to a 60 MW combustion turbine would provide  
8 approximately 127 MVAR of reactive power when operated in synchronous  
9 condenser mode. Consequently, a single larger electric generator connected to the  
10 nominal 60 MW combustion turbine would ensure acceptable operation of the LIL.