

1 Q. The third paragraph at page 9 of the Report entitled "*Supply and Install 100 MW*  
2 *(Nominal) of Combustion Turbine Generation*", April 10, 2014, indicates that the  
3 installation schedule for the combustion turbine is very condensed. What is the  
4 normal time that Hydro would allow for the procurement and installation of a large  
5 capital expenditure such as the 100 mW combustion turbine generator?

6

7

8 A. Hydro has not previously procured and installed a 100 MW combustion turbine. In  
9 the case of a new 100 MW combustion turbine generator, Hydro estimates that it  
10 would allow 24 months to complete (procure and install) a project of this  
11 magnitude. In the case of a readily available aftermarket plant, Hydro estimates  
12 that it would require up to 18 months to procure and install.