



Newfoundland Power Inc.

55 Kenmount Road
P.O. Box 8910
St. John's, NL A1B 3P6
Business: (709) 737-5600
Facsimile: (709) 737-2974
www.newfoundlandpower.com

HAND DELIVERED

July 4, 2014

Board of Commissioners
of Public Utilities
P.O. Box 21040
120 Torbay Road
St. John's, NL A1A 5B2

Attention: G. Cheryl Blundon
Director of Corporate Services
and Board Secretary

Ladies and Gentlemen:

**Re: Newfoundland and Labrador Hydro 2014 Capital Budget Supplemental –
Western Avalon Terminal Station T5 Tap Changer Replacement – Requests for
Information**

Please find enclosed the original and 12 copies of Newfoundland Power's Request for Information NP-NLH-001 in relation to the above noted Application.

For convenience, the Requests for Information are provided on three-hole punched paper. A copy of this letter, together with enclosures, has been forwarded directly to the parties listed below.

If you have any questions regarding the enclosed, please contact the undersigned at your convenience.

We trust this is in order.

Yours very truly,

Gerard M. Hayes
Senior Counsel



c. Geoffrey Young
Newfoundland and Labrador Hydro

Thomas Johnson
O'Dea Earle Law Offices

Paul Coxworthy
Stewart McKelvey

Thomas O'Reilly, QC
Vale Newfoundland and Labrador Limited

Roberta Frampton Benefiel
Grand Riverkeeper Labrador Inc.

Sheryl Nisenbaum
Praxair Canada Inc.

Danny Dumaresque



IN THE MATTER OF the *Electrical Power Control Act*, R.S.N.L. 1994, Chapter E-5.1 (the *EPCA*) and the *Public Utilities Act*, R.S.N.L. 1990, Chapter P-47 (the *Act*), and regulations thereunder;

AND IN THE MATTER OF an Application by Newfoundland and Labrador Hydro pursuant to Subsection 41(3) of the *Act*, for the approval of the replacement of the tap changer on transformer T5 at the Western Avalon Terminal Station.

**Requests for Information by
Newfoundland Power Inc.**

NP-NLH-001

July 4, 2014

Requests for Information

NP-NLH-001

On Page 20 of 20 to Appendix B of Hydro's *Replace T5 Tap Changer Western Avalon Terminal Station* report, ABB recommends adding a diaphragm to the transformer's oil conservator. Is Hydro adding a diaphragm to the conservator? If not, please explain.

RESPECTFULLY SUBMITTED at St. John's, Newfoundland and Labrador, this 4th day of July, 2014.



NEWFOUNDLAND POWER INC.
P.O. Box 8910
55 Kenmount Road
St. John's, Newfoundland A1B 3P6

Telephone: (709) 737-5609
Telecopier: (709) 737-2974