

1 Q. Re: **Upgrade Transmission Line Corridor Bay d’Espoir to Western Avalon**, Page 12.
2 Hydro indicates “The criteria applied here permits controlled loss of load to
3 maintain stability for loss of the HVdc bipole...”.
4 Please provide a complete description of the extent to which load is assumed to be
5 reduced to maintain stability for the loss of the HVdc link in this aspect of Hydro’s
6 analysis.

7
8
9 A. Under a temporary, or momentary, loss of the bipole, there is no planned loss of
10 load on the Island Interconnected System as the HVdc Link will restart and supply
11 pre-event load levels.

12
13 For the permanent loss of the bipole, there will be a loss of supply over the HVdc
14 Link and as such it will be necessary to shed load on the Island Interconnected
15 System to re-balance load with on island generation in order to maintain acceptable
16 system frequency, and subsequently, system stability. The magnitude of the load
17 loss for the Island Interconnected System is dependent upon the loading of both
18 the Labrador – Island HVdc Link (LIL) and the Maritime Link (ML). For issues with
19 the LIL, including the permanent loss of the bipole, the ML load will be curtailed to
20 assist with ensuring stable operation of the Island Interconnected System. With ML
21 being curtailed, the magnitude of load to be curtailed on the island will be the
22 difference between the LIL load and the ML load. For example, if LIL is delivering
23 500 MW at Soldiers Pond and ML is loaded to 155 MW at Bottom Brook, under
24 permanent loss of the bipole the 155 MW on ML would be curtailed and the load
25 reduction on the island would equal 345 MW. If there is no load on ML at the time
26 of the permanent LIL bipole outage, the entire loading on LIL equals the required
27 load reduction on the island.