

1 Q. Re: **Upgrade Transmission Line Corridor Bay d’Espoir to Western Avalon**, Pages 27-  
2 28 and 52-53.

3 If generators were installed to provide synchronous condenser capabilities as  
4 opposed to simple synchronous condensers, would the proposed 230 kV  
5 transmission line still be required to ensure system stability? In the response, please  
6 indicate the technical and/or cost considerations justifying the conclusion.

7

8

9 A. As noted in Hydro's response to NP-NLH-007, the 175 MVAR synchronous  
10 condensers cannot be considered simple synchronous condensers given the high  
11 inertia constant and the cost impact of providing the same level of inertia with  
12 typical simple cycle combustion turbines with synchronous condenser capability.

13

14 The analysis provided in this Application demonstrates that the addition of multiple  
15 high inertia synchronous condensers without the new Bay d’Espoir to Western  
16 Avalon 230 kV transmission line, in and of itself, does not provide a technically  
17 viable solution to maintain Island Interconnected System stability. Given that the  
18 response to NP-NLH-007 demonstrates a need for eighteen simple cycle  
19 combustion turbines with synchronous condenser capability for every two 175  
20 MVAR high inertia synchronous condensers at a estimated cost of \$2.7B, then  
21 increasing the number of synchronous condensers beyond the existing level to  
22 avoid the construction of the proposed new 230 kV transmission line is, by  
23 comparison, cost prohibitive.

24

25 Operation of generators instead of synchronous condensers on the Avalon  
26 Peninsula to maintain system stability would mean burning fuel and effectively  
27 reducing hydroelectric imports from Labrador. The shutdown of existing on-island

- 1 thermal resources for generation of power and energy has been determined to be
- 2 the least cost option for long-term supply of the Island Interconnected System.