

1 Q. Re: **Upgrade Transmission Line Corridor Bay d’Espoir to Western Avalon**, Page 35.
2 Please provide a comparison of transient stability before (i.e., in the current system
3 configuration) and after the addition of the Labrador-Island HVdc Link (i.e., prior to
4 the proposed 230 kV transmission line). In your response, please indicate the
5 sources of potential instability which Hydro assesses as significant.

6
7
8 A. When comparing the transient stability of the existing system with the transient
9 stability of the system after the addition of the Labrador-Island HVdc Link, one must
10 consider the impacts of replacing active power generation at the Holyrood Thermal
11 Generating Station with the supply from an HVdc converter station at Soldiers
12 Pond. With this replacement, the system is fundamentally changed in its response
13 to faults.

14
15 As discussed in Hydro's response to IC-NLH-006, a critical fault for the existing
16 system is a three-phase fault at Holyrood under peak load conditions. As discussed
17 in Hydro's response to IC-NLH-006, a critical fault for the system following the HVdc
18 interconnection is a three-phase fault at Bay d’Espoir under peak load conditions.
19 Without the proposed 230 kV transmission line between Bay d’Espoir and Western
20 Avalon, other faults in this corridor also become critical faults. An example of this is
21 discussed on page 35 of the report.

22
23 As discussed on page 12 of the report, severe faults can cause a temporary
24 shutdown of the Soldiers Pond converter (commutation failure) and, at the same
25 time, the electrical power from the Bay d’Espoir Generating Station feeds into the
26 fault. Without any generation at Holyrood and an interrupted supply from the HVdc
27 link, the deficit of reactive power on the Avalon Peninsula results in instability.

1 With the new 230 kV transmission line between Bay d’Espoir and Western Avalon,
2 the system is reinforced such that rotating machines on the Avalon Peninsula can
3 maintain synchronism following a disturbances within the Bay d’Espoir to Western
4 Avalon corridor (with the exception of a three-phase fault at Bay d’Espoir under
5 peak load conditions with one high inertia synchronous unavailable).