

1 Q. Further to PUB-NLH-12 does the loss of either of the existing gas turbines at
2 Hardwoods or Stephenville or the synchronous condenser at Holyrood create a
3 stability problem for the system after the Labrador Island Link is placed in service?
4

5
6 A. The loss of either of the existing gas turbines at Hardwoods or Stephenville or the
7 synchronous condenser at Holyrood will not result in a stability problem for the
8 system after the Labrador-Island Link is placed in service.
9

10 As discussed in the report, the loss of a synchronous condenser at Soldiers Pond
11 does not result in a stability problem. The loss of one of these units is a more severe
12 contingency than the loss of one of the units described above, as the Soldiers Pond
13 machines have a higher reactive power rating as well as a higher inertia. These
14 values are summarized in the table below:
15

Unit	Maximum Reactive Power Output (MVAR)	Inertia (MW-s)
Soldiers Pond SC	175.0	1372.0
Holyrood SC	166.0	157.6
Hardwoods GT	63.3	130.5
Stephenville GT	63.5	130.8