

1 Q. Numerous overload conditions on the 230kV system are noted in section 6 of the
2 Upgrade Transmission Line Corridor Report for post contingency situations. Are
3 each of these overloads present on the existing system for the same or similar
4 contingencies? Explain your response in detail.

5
6

7 A. All transmission studies completed in the Upgrade Transmission Line Corridor
8 Report were completed assuming the integration of a 900 MW HVdc bipole
9 transmission system between the Muskrat Falls Hydro development and the
10 proposed Soldier's Pond Terminal Station on the Avalon Peninsula.

11

12 For the existing isolated Island Interconnected System, many of these, or similar,
13 overloads could exist post contingency without mitigative actions. Today, operators
14 follow documented operating instructions to dispatch hydro and thermal
15 generation on the Island to manage the power flows on the 230 kV transmission
16 lines east of Bay d'Espoir. The instructions are designed to ensure that following a
17 transmission line contingency flows in all remaining lines are maintained at or
18 below their calculated thermal ratings when the available standby emergency
19 generation (i.e., Hardwoods combustion turbine) has been brought online. The
20 operating instructions allow adjustment to the transmission line thermal ratings
21 depending on the ambient temperature and specify generation dispatches on either
22 end of the Bay d'Espoir – Western Avalon transmission line corridor to limit power
23 transfer at a particular system load.

24

25 The base cases used in the analysis contained within the Report were tested to
26 identify the limitations during contingencies and ensure that any resultant
27 overloading can be mitigated with the available system resources.