

1 Q. Has Hydro given consideration to upgrading the overloaded lines which are outlined
2 in section 6.2.1 of the Upgrade Transmission Line Corridor Report through the use
3 of composite conductors that could accept higher current (and conductor
4 temperature) without increased sag? If yes, explain how. If no, why not?

5
6
7 A. Hydro did not consider upgrading the conductor on the overloaded lines outlined in
8 Section 6.2.1 of the report with composite conductors, as the installation of a third
9 230 kV transmission line between Bay D'Espoir (BDE) and Western Avalon (WAV)
10 eliminates transmission overloads east of BDE under a single contingency event.
11 Furthermore, the installation of a third 230 kV transmission circuit east of BDE is
12 justified on the transient stability performance as opposed to the steady state load
13 flow analysis and transmission line thermal overloads. The transmission line
14 corridor upgrade strengthens the Island Interconnected System to survive electrical
15 disturbances following the integration of the Labrador-Island Link, while providing
16 increased transmission capacity east of BDE and operational flexibility during a
17 single contingency event.