

1 Q. On page 26 of the Upgrade Transmission Line Corridor Report it is noted that for
2 maximum hydraulic generation and reduced Labrador Island Link imports at
3 Soldiers Pond, voltage collapse will occur for the loss of either TL202 or TL206. How
4 is this different from the existing system with maximum hydraulic generation? If
5 there is no difference, how does Hydro manage such a condition with the existing
6 system and why wasn't this addressed before?

7
8
9 A. On page 26 of the Report, reference is made to voltage collapse of the system for
10 loss of TL202 or TL206 for maximum hydraulic generation and minimum Labrador-
11 Island Link import power orders. This is due to the system impedance of the Bay
12 d'Espoir – Western Avalon transmission corridor and insufficient reactive support
13 on the Avalon Peninsula to overcome the substantial voltage drop under this
14 transmission configuration and contingency.

15
16 For the existing system, voltage collapse following the loss of TL202 or TL206 is not
17 an issue as the system is operated to avoid thermal overload of the corridor
18 through coordinated operation of the Holyrood Thermal Generating Station and
19 reduced operation of the hydraulic generation. In essence, the potential for voltage
20 collapse for loss of TL202 or TL206 is mitigated within the existing system by not
21 operating with maximum hydraulic generation.