

1 Q. On page 56 of the Upgrade Transmission Line Corridor Report, the second
2 paragraph ends with the statement “....if there were major issues at Sunyside, there
3 would be a high capacity circuit through the isthmus of Avalon that would be
4 unaffected by such issue”. Please describe the types of events that are envisioned
5 by the term “major issue”.

6

7

8 A. Major issues with the Sunnyside Terminal Station are deemed to include
9 contingencies that extend beyond the normal single element, or N-1, contingency
10 including: simultaneous loss of both TL202 and TL206; fire causing complete loss of
11 the Sunnyside Terminal Station control building; and catastrophic loss of the entire
12 Sunnyside Terminal Station.