

1 Q. Please describe the type(s) of circuit breakers to be installed at Bay d' Espoir  
2 referred to on pages 63-65 of the Upgrade Transmission Line Corridor Report.

3

4

5 A. The type of circuit breakers to be installed at Bay D'Espoir referred to on pages 63-  
6 65 of the Upgrade Transmission Line Corridor Report is Sulphur Hexafluoride or the  
7 SF<sub>6</sub> type.