

1 Q. On page 67 of the Upgrade Transmission Line Corridor Report Hydro states that
2 there are no issues of these three circuits sharing a common corridor. Is this
3 consistent with operating experience of the three 230 kV circuits sharing the
4 corridor between Churchill Falls and Montagnais (Hydro Quebec)?
5
6

7 A. On page 67 of the Upgrade Transmission Line Corridor Report, Hydro is discussing
8 the transmission line corridor through the Bay Du Nord Wilderness Reserve
9 (BDNWR) and the prospect of adding a third transmission line to the existing right
10 of way within the reserve. Hydro states:
11

12 *“From a utility perspective, while route diversity is a positive for weather related*
13 *outages, this corridor has not been an issue with respect to ice storms or wind*
14 *damage. It is the preferred course of action as there is no evidence to support a*
15 *high probability of common mode failures. The cost of avoiding the reserve could*
16 *exceed \$60M.”*
17

18 Hydro’s operating experience within the BDNWR has not provided evidence that
19 there will be a high probability of common mode failure in that geographic region.
20 Hydro’s operating experience on the Isthmus and on the Avalon Peninsula with
21 respect to weather related events such as ice storms and wind damage have
22 resulted in changes to the meteorological loadings used for transmission line design
23 for lines on the Avalon Peninsula vis-à-vis the Avalon Transmission Line Upgrade
24 Project completed in the late 1990s early 2000s.
25

26 While route diversity for transmission lines does provide benefit with respect to
27 reliability of supply, such diversity must also consider the cost and practicality of

1 such diversity. Routing the transmission line around the BDNWR is estimated to
2 increase capital cost by \$60M for this section alone. Further increases in capital
3 cost would be expected as a new, remote right of way would have to be cut to
4 provide the route diversity. From a practical point of view, route diversity to avoid
5 common mode failures due to weather related events for overhead transmission
6 lines across the Isthmus of the Avalon is difficult given the limited width of the
7 Isthmus and potential for local weather to impact the entire Isthmus at once.

8
9 Hydro acknowledges that the operating experience of the three 735 kV circuits
10 between Churchill Falls and Hydro-Québec TransÉnergie's Montagnais Substation in
11 a common corridor has demonstrated a number of common mode failures resulting
12 in the loss of all three 735 kV transmission lines with subsequent loss of load in
13 Québec.

14
15 With respect to the impact of loss of all transmission lines in a common corridor,
16 NERC transmission planning standard TPL-004-0a entitled "System Performance
17 Following Extreme Events Resulting in the Loss of Two or More Bulk Electric System
18 Elements (Category D)" covers this contingency. Table 1 of the TPL-004-0a standard
19 Category D events are described as "Extreme event resulting in two or more
20 (multiple) elements removed or Cascading out of service". Category D contingency
21 7 is the loss of all transmission lines on a common right-of-way. Table 1 of the
22 standard indicates that Category D events are evaluated for risks and consequences
23 that may include substantial loss of customer load or generation across widespread
24 areas with portions of the interconnected system not achieving a stable operating
25 point following the event.

26
27 Hydro's interpretation of the NERC TPL-004-0a standard is that loss of all (i.e., two
28 or more) transmission lines in a common corridor is an extreme contingency during

- 1 which the impact of the event on the transmission system is to be considered but
- 2 loss of load is acceptable.