

1     Q.     Please refer to Appendix C10, section 3.13, page 26. The power order reduction  
2           scheme referred to would require telecommunications. Please state whether there  
3           would be redundancy in the telecommunications systems required.

4

5

6     A.     The will be two independent telecommunications links between Churchill Falls and  
7           Muskrat Falls. These links include an existing ADSS fibre optic link between the  
8           stations and an optical ground wire that will be installed on one of the two new 315  
9           kV transmission lines.