

1 Q. **Tab C, 2014 Capital Projects \$500,000 and Over: Explanations – Install Fire**  
2 **Protection System, p. C-58**

3 For the Nain fire protection system project, will it be necessary to add an extension  
4 to the building to house the fire suppression equipment as potentially noted by  
5 Hatch in its report at A-29 (Vol. II, Tab 22)?  
6  
7

8 A. It will not be necessary to add an extension to the building to house the fire  
9 suppression equipment. It is intended to house the fire suppression equipment  
10 inside the existing building.