

1 Q. **Tab 23, Upgrade Diesel Plant Production Data Collection Equipment, Various Sites**

2 At p. 6, Hydro outlines the manual retrieval of data is done at the end of the month.

3 Has Hydro looked into the option of increasing the frequency of the manual

4 documentation?

5

6

7 A. Hydro has considered the option of increasing the frequency of manual

8 documentation, but does not see a lot of benefit in it.

9

10 For the benefits sought, sub-hourly data is required.