

1 Q. **Tab D, 2014 Capital Projects \$200,000 and over but less than \$500,000:**

2 **Explanations – Inspect Fuel Storage Tanks, p. D-114**

3 At p. D-121, API outlines that all tanks shall be given a visual external inspection by  
4 an authorized inspector. How many employees at Hydro are authorized inspectors?

5

6

7 A. There are no authorized API inspectors within Hydro.