

1 Q. **Project C-24, Upgrade Plant Elevators – Holyrood**

2 On page 6 of the report filed at Volume II, Tab 10, Hydro provides examples from
3 February 2010, August 2009 and May 2006 when people were trapped in the
4 elevators. Have there been any incidents recorded since 2010? Has Hydro
5 implemented any measures to reduce the likelihood of such events?
6
7

8 A. There have been no similar incidents since 2010. In an effort to keep the elevators
9 safe until upgrade in 2014, Hydro has increased the number of inspections by the
10 service provider. However, the equipment has now deteriorated to the point
11 where an upgrade is necessary.