

1 Q. **Project C-24, Upgrade Plant Elevators – Holyrood**

2 Will these elevators experience the same level/frequency of usage after Holyrood is
3 converted to synchronous condenser mode? Explain why one elevator would not
4 suffice to provide necessary access after Holyrood is converted to synchronous
5 condenser mode.

6

7

8 A. These elevators will not experience the same level/frequency of usage after
9 Holyrood is converted to synchronous condenser but they must be safe for
10 operation regardless. Neither of these elevators can serve both functions. The
11 administration elevator cannot be used to transport tools because it is of
12 insufficient capacity and size. The powerhouse elevator cannot be used to
13 transport visitors to site as they would have to traverse the powerhouse and be
14 exposed to unnecessary hazards to gain access to the elevator.

15

16 Please also see the response to V-NLH-23.