

1 Q. **Project C-52, Upgrade Distribution Systems**

2 Does any of the work in Project C-48 and the ten individual distribution upgrade
3 projects described therein overlap with this project? Why or why not?

4

5

6 A. The work in the project located at page C-48 does not overlap with the work
7 outlined in the project located at page C-52. The project located at page C-52 is an
8 annual allotment which is adjusted from year to year depending on historical
9 expenditures. That annual allotment is spent on upgrading which is identified
10 through preventive maintenance, or other inspections in the execution year, and it
11 is also used when there is damage caused by storms, other adverse weather
12 conditions or salt contamination among other things, whereas the project located
13 at page C-48 is planned capital upgrade work.