

1 Q. **Project C-62, Overhaul Diesel Engines**

2 Is 20,000 hours on par with industry practice for this type of project?

3

4

5 A. The 20,000 hour overhaul interval is on par or greater than that of other Canadian  
6 utilities. In a survey completed in 2007, the following information was received  
7 from other utilities regarding their overhaul interval:

8 • Hydro One – 20,000 hours for 1,800 RPM engines;

9 • Manitoba Hydro – 16,000 hours for 1,800 RPM engines; and

10 • Hydro Quebec – 15,000 hours for 1,800 RPM engines.