

1    Q.    **Reference:    Volume I, 2014 Capital Projects Overview, Page 7**

2            What will Gross and Net Generator Capacities of both the Hardwoods Gas Turbine  
3            and Stephenville Gas Turbine be following each unit's planned refurbishment?

4

5

6    A.    Following each unit's refurbishment, the net capacity of both Stephenville and  
7            Hardwoods Gas Turbine will be 50 MW. There is no anticipated change in the units'  
8            capacity as a result of the planned refurbishment projects. Hydro does not retain  
9            station service demand data for its gas turbines.