

1 Q. **Reference: Volume I, 2014 Capital Projects Overview, Page 7**

2 It is indicated that the "...refurbishment of the Hardwoods Gas Turbine is now
3 substantially complete...". Please indicate when this work was substantially
4 completed and what remains to be completed.

5

6

7 A. The refurbishment of the Hardwoods Gas Turbine has been ongoing over the last
8 four years. The work was substantially completed at the end of 2012, with some
9 work being carried over to 2013. The work remaining to be completed includes:

- 10 • Replacement of 13.8 kV Breaker;
- 11 • Replacement of 15 kV power cable;
- 12 • Installation of new fuel valve on End A engine;
- 13 • Installation of new ignition boxes for both engines;
- 14 • Recoat exterior and interior of exhaust stacks and inlets, cooler, alternator
15 enclosure; and
- 16 • Installation of main lube oil pumps and motors.