

1 Q. **Reference: Volume I, Holyrood Overview Future Operations and Capital**
2 **Expenditure Requirements**

3 Please indicate the period or periods over which Hydro expects to recover forecast
4 capital expenditures for the Holyrood facility that are made in the period 2013
5 through 2021.

6
7
8 A. The recovery period for the forecast capital expenditures for Holyrood is dependent
9 on whether the assets will be used for synchronous condenser mode after the
10 Labrador infeed. Expenditures related to assets that will be used for synchronous
11 condenser mode will have the same recovery period as other similar assets
12 throughout the Hydro system, in accordance with Hydro's approved average service
13 lives. Otherwise, the recovery period ends when the plant is no longer required to
14 be available for generation in standby mode, currently estimated to be 2020.