

1 Q. **Reference: Install Handheld Pendant to Overhead Crane, Volume I, Section D,**  
 2 **Page D-98.**

3 Please complete the table below:

	2008	2009	2010	2011	2012
# of hours cab of overhead crane was occupied.					

4

5

6 A. Hydro does not formally record the number of hours that the cab of the overhead  
 7 crane is occupied. An estimate is provided based on the following information:

- 8 • Each two week annual outage required about 20 hours of crane operation per  
 9 week;
- 10 • Each generating unit overhaul requires about 30 hours per week for three  
 11 weeks;
- 12 • The generator stator rewinds have typically required approximately 250 hours  
 13 of crane operation;
- 14 • For the remainder of the year, there are typically two or three hours of crane  
 15 operation per week;
- 16 • In 2008 there were six annual inspections; in 2009 there were two major  
 17 inspections and four annual inspections; in 2010 there was one rewind and five  
 18 annual inspections; in 2011 there was one major inspection and five annual  
 19 inspections; and in 2012 there was one rewind and five annual inspections.

	2008	2009	2010	2011	2012
Estimated hours overhead crane cab was occupied	300	400	500	400	500