

1 Q. **Reference: Plan of Projected Operating Maintenance Expenditures for**
2 **Holyrood Generating Station 2014 – 2023, Volume I, Section J, Appendix B, Page**
3 **B2**

4 Please describe the work included under the headings of Boiler O/H during the
5 period from 2021 to 2022 when the Holyrood facility is scheduled to be
6 decommissioned.

7
8
9 A. In the 2020-2021 timeframe it is anticipated that the remaining fuel inventory left
10 at Holyrood will be consumed. The boiler overhaul work to be performed in 2021
11 and 2022 consists of the following activities:

- 12 • Removal of ash;
- 13 • Boiler waterwall and tube cleaning;
- 14 • Dust control mitigation;
- 15 • Work required to ensure safety of personnel;
- 16 • Work required to ensure environmental compliance;
- 17 • Asbestos abatement; and
- 18 • Isolation activities to enable start of de-commissioning work.

19
20 This is the current maintenance plan for Holyrood, however, this work will not be
21 completed unless deemed necessary, and will be reconsidered as the time
22 approaches.