

1 Q. **Reference: Condition Assessment and Life Extension – Holyrood, Volume II,**
2 **Report 8.**

3 What is the estimated end of service life of Unit 3 once it is converted to
4 synchronous condenser mode in 2021?

5

6

7 A. The estimated end of service life of Unit 3 once it is converted to synchronous
8 condenser mode in 2021 has not been fully established, but it is considered to be
9 sometime beyond 2041.