

1 Q. **Reference: Upgrade Power Transformers – Various Sites, Volume II, Report 16**

2 It is indicated that Hydro’s methodology to determine transformer refurbishment or
3 replacement is “...aligned with procedures of other North American utilities with
4 similar transformer assets.” (p. i)

5 Please provide details of this alignment including a listing of the other North
6 American utilities to which Hydro is comparing its methodology.

7

8

9 A. The alignment of Hydro’s methodology to other North American utilities include the
10 following:

11 i) Oil Quality and Dissolved Gas Analysis – Utilities take regular oil samples
12 from their transformers to determine the condition of the oil to determine
13 whether refurbishment work (oil reclamation or oil replacement is
14 required). As well utilities also test for Furans to help determine the strength
15 remaining in the paper (insulation system) to help determine end of life and
16 plan for its replacement. This approach is consistent with Hydro One, BC
17 Hydro and Manitoba Hydro.

18 ii) Transformer Leak Repair (Gasket Replacement) – Due to the age of power
19 transformers in service, many utilities have put plans in place to help
20 eliminate oil leaks from power transformers to minimize the impact to the
21 environment. Replacing gaskets on power transformers has been done by
22 other utilities including Hydro One, BC Hydro and Newfoundland Power.

23 iii) Bushing Replacement – Due to the possibility of transformer bushings
24 containing PCBs in concentrations greater than 500 ppm, there is a
25 requirement to have them replaced and disposed of appropriately. This
26 requirement is legislated and is currently required to be followed by all
27 Canadian Utilities.