

1 Q. **Reference: Upgrade Diesel Plant Production Data Collection Equipment –**
2 **Various Sites, Volume II, Report 23**

3 Is this project economically justified? If it is not, explain why it should not be
4 economically justified.

5

6

7 A. This project is not directly economically justified. However, the data collected as a
8 result of this project will be used to produce better economic justifications for
9 future equipment replacements in Hydro's isolated systems.

10

11 Timely production data will provide the necessary data for Hydro's operations and
12 system planning purposes. Currently, the data is typically retrieved on a monthly
13 basis and does not provide the sampling rate to provide detailed plant load profiles.

14

15 The more accurate and detailed the data that is available, the more confidence
16 there is in the results of studies and thus the longer system upgrades can be
17 delayed without exceeding criteria. With coarser data to work with, decisions have
18 to be more conservative, and sometimes, system upgrades have to be carried out
19 sooner. On multi-million dollar generation upgrade projects, being able to delay a
20 project by as little as one year can lead to savings of tens of thousands to hundreds
21 of thousands of dollars.

22

23 The increased detail of the data collected will also be used to improve planning in a
24 number of areas:

1 a) Forecasting

2
3 Having access to detailed demand information facilitates annual peak forecasting
4 efforts by allowing for the normalization of weather, day of week and cold load
5 pick-up effects on actual peak demands. The increased demand detail will also
6 provide a better understanding of isolated system demands which can then be
7 applied to predicting demand by hour and day of week which aids unit sizing for
8 capacity additions or unit replacements.

9
10 As well, the increasing presence of electric heat in Hydro's isolated systems is
11 changing the historical typical load shape. Having detailed information will better
12 allow Hydro to predict the consequences of these changes, such as determining if
13 current criteria for the requirement of additional generation are in need of
14 adjustment.

15
16 b) Unit Sizing

17
18 The availability of more detailed production data will enable the optimization of the
19 sizing of new diesel generation units, to give the minimum life cycle cost for the
20 new unit and for the entire diesel plant in which it will be installed.

21
22 First, the unit can be sized to maximize fuel efficiency among all the units in the
23 plant. Second, as unit maintenance intervals and replacements, and thus costs are
24 based on unit operating hours, units can be sized to minimize total unit operating
25 hours in a plant.

26
27 It is preferred that the output of a diesel unit should not fall below 30 percent of
28 the prime power rating for any length of time. Operating a diesel unit at 30 percent

1 or less of its prime power rating is inefficient and may lead to the emission of soot
2 into the local environment, which has a negative effect on the near-by community
3 and its residents. Having access to detailed plant output data would aid in
4 determination of the minimum loading on the diesel plant. This would enable sizing
5 of units to avoid this condition. As well, in cases where the load in a community is
6 declining, it would aid in pinpointing when action needs to be taken to avoid this
7 condition.

8
9 c) Studies

10
11 Hydro is looking at the option of having renewable energy sources, such as wind
12 and hydro, supplying energy to its isolated systems. The more detailed picture of
13 system load that is available, the more that use of alternative energy sources can be
14 maximized. In addition, the increased metering detail will allow for more accurate
15 pre-impact and post-impact analysis for evaluating demand management programs
16 within isolated diesel communities.

17
18 Finally, any models used to study the system can be better correlated to actual
19 operating data.