

1 Q. **Reference: Additions to Accommodate Load Growth – Hopedale, Volume II,**
2 **Report 25, Page 13, Table 10**

3 Please provide an explanation of the forecasted 17% increase in net peak from 2013
4 to 2014.

5

6

7 A. The forecasted increase in net peak from 2013 to 2014 is primarily the result of the
8 Nunatsiavut Government plan to construct a new 1,200 square meter facility that
9 will use electricity for space heating. This facility has an estimated connected load
10 of 435 kW including 135 kW for electric heat. The Hopedale load forecast for the
11 year 2014 also includes the requirements for an additional five new domestic
12 customers and an additional 16 megawatt hours of small general service load.